



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX BAS 23.0011** Page 1 of 4 Certificate history:
Status: **Current** Issue No: 2 [Issue 1 \(2023-12-18\)](#)
[Issue 0 \(2023-05-05\)](#)
Date of Issue: 2025-07-09
Applicant: **Eaton Electric Limited**
Great Marlings
Butterfield
Luton
Bedfordshire
LU2 8DL
United Kingdom
Equipment: **MTL4500 & MTL5500 Series Galvanic Isolators – Digital In modules**
Optional accessory:
Type of Protection: **Intrinsic Safety**
Marking: **[Ex ia Ga] IIC**
[Ex ia Da] IIIC
[Ex ia Ma] I

-20°C ≤ Ta ≤ +60°C – All Models
-20°C ≤ Ta ≤ +65°C – MTL5514-T Model only

Approved for issue on behalf of the IECEx
Certification Body:

M Powney

Position:

Engineering Manager

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

SGS UK Limited
Rockhead Business Park
Staden Lane
Buxton, Derbyshire SK17 9RZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 23.0011**

Page 2 of 4

Date of issue: 2025-07-09

Issue No: 2

Manufacturer: **Eaton Electric Limited**
Great Marlings
Butterfield
Luton
Bedfordshire
LU2 8DL
United Kingdom

Manufacturing locations: **Eaton Electric Limited**
Great Marlings
Butterfield
Luton
Bedfordshire
LU2 8DL
United Kingdom

Eaton Electric India Private Limited
No 3 Old Mahabalipuram Road,
Sholinganallur,
Chennai 600119
India

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-11:2011](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/BAS/ExTR23.0017/00](#)

[GB/SGS/ExTR23.0149/00](#)

Quality Assessment Reports:

[GB/BAS/QAR06.0022/11](#)

[GB/BAS/QAR07.0017/11](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 23.0011**

Page 3 of 4

Date of issue: 2025-07-09

Issue No: 2

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

This certificate covers the following types:

- MTL4501-SR Failsafe Switch / Proximity Detector Interface.
- MTL4504 / MTL4511 / MTL4514 / MTL4514B / MTL4516 / MTL4516C / MTL4517 Switch / Proximity Detector Interface.
- MTL4510 / MTL4510B / MTL4513 Switch / Proximity Detector Interface.
- MTL4514D Single Channel Switch / Proximity Detector Interface with Dual Output, Line Fault Detection & Phase Reversal.
- MTL4514N / MTL4514X Switch / Proximity Detector Interface with Line Fault Detection Alarm.
- MTL5501-SR Failsafe Switch / Proximity Detector Interface.
- MTL5510 / MTL5510B / MTL5513 Switch / Proximity Detector Interface.
- MTL5511 / MTL5514 / MTL5514-T / MTL5516C / MTL5517 Switch / Proximity Detector Interface.
- MTL5514D Single Channel Proximity Detector Interface with Dual Output, Line Fault Detection & Phase Reversal.

See Certificate Annex for a description of the types of equipment and electrical parameters.

SPECIFIC CONDITIONS OF USE: NO



IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 23.0011**

Page 4 of 4

Date of issue: 2025-07-09

Issue No: 2

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Variation 2.1

To update the alternative manufacturer's name

File Reference: **25/0195**

Annex:

[IECEX BAS 23.0011 Annex1.pdf](#)

Schedule 1 – MTL4501-SR Failsafe Switch / Proximity Detector Interface

The MTL4501-SR Failsafe Switch / Proximity Detector Interface is designed to provide an interface between unspecified non-hazardous area apparatus and an intrinsically safe circuit in the hazardous area. The apparatus is intended to provide a galvanically isolated fail-safe safe-area output whilst monitoring a fail-safe proximity switch detector located in the hazardous area. Line Fault Detection (LFD) in the apparatus is provided by volt-free relay contact output on the nonhazardous area side of the apparatus. Two transformers and a relay provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The apparatus comprises two isolating transformers, a relay, fuses, zener diodes and resistors to provide voltage and current limitation. The above, together with other electronic components are mounted on a printed circuit board and housed in a moulded plastic enclosure. Polarised plugs and sockets are provided for hazardous and non-hazardous area connections. LED indication is provided for power-on, the output status and line fault detection.

Input / Output Parameters

Non-Hazardous Area Terminals 7, 8, 10, 11, 13 & 14

$U_m = 253V \text{ r.m.s.}$

The circuit connected to non-hazardous area terminals 13 & 14 is designed to operate from a d.c. supply voltage of up to 35V.

The non-hazardous area terminals 10 & 11 are connected to relay contacts which can switch up to 253V r.m.s, 2A r.m.s and 100VA

Hazardous Area Terminals 1 & 2

$U_o = \pm 9.7V$ $C_i = 0$
 $I_o = 30mA$ $L_i = 0$
 $P_o = 0.07W$

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load connected must not exceed the following values for either channel:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR L/R RATIO ($\mu H/ohm$)
IIC	3.5	39	475
IIB*	24	145	1,829
IIA	170	299	3,093
I	320	501	6,414

* Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is < 1% of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.
- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is \geq 1% of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is \geq 1% of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than 1 μF for Groups IIB, IIA & I and 600nF for Group IIC.

Schedule 2 – MTL4504 / MTL4511 / MTL4514 / MTL4514B / MTL4516 / MTL4516C / MTL4517 Switch / Proximity Detector Interface

The MTL4504 / MTL4511 / MTL4514 / MTL4514B / MTL4516 / MTL4516C / MTL4517 Switch / Proximity Detector Interface are designed to restrict the transfer of energy from unspecified non-hazardous area apparatus to up to two intrinsically safe circuits by limitation of voltage and current. Relays and a transformer provide galvanic isolation between the hazardous and non-hazardous area circuitry.

Each channel of the interface monitors either a detector or switch located in the hazardous area and controls non-hazardous area loads via relays. Some models of the interface are fitted with independent phase reverse controls and Line Fault Detection (LFD) circuitry allow an alarm condition to be signalled for either state, set by switches on the side of the interface.

The apparatus comprises an isolating transformer, relays, zener diodes and current limiting resistors to provide voltage and current limitation on each channel. These, together with other electronic components are mounted on a single printed circuit board and housed in a plastic enclosure. Polarised plugs and sockets are provided for connection to the hazardous and non-hazardous area. LED indication is provided to indicate Power-on, state of the outputs and LFD status.

The above listed models are all built on a common printed circuit board. The differences between the models relates to the configuration of relays and non-hazardous area connections.

Model Range

Model No.	
MTL4504	Single Channel Switch / Proximity Detector Interface with Line Fault Detection (LFD) & Phase Reversal
MTL4511	Single Channel Switch / Proximity Detector Interface
MTL4514	Single Channel Switch / Proximity Detector Interface with Line Fault Detection (LFD) Alarm
MTL4514B	Single Channel Switch / Proximity Detector Interface with Line Fault Detection (LFD) & Phase Reversal
MTL4516	Dual Channel Switch / Proximity Detector Interface
MTL4516C	Dual Channel Switch / Proximity Detector Interface
MTL4517	Dual Channel Switch / Proximity Detector Interface with Line Fault Detection (LFD) Alarm

Input / Output Parameters

Non-Hazardous Area Terminals 7 to 14

$$U_m = 253V \text{ r.m.s.}$$

The circuit connected to non-hazardous area terminals pins 13 & 14 are designed to operate from a d.c. supply voltage of up to 35V.

Non-hazardous area terminals pins 7 to 12 are connected to relay contacts which can switch up to 253V r.m.s, 2A r.m.s and 100VA.

Hazardous Area Terminals 1 w.r.t. 2 / 3 (Channel 1)
Hazardous Area Terminals 4 w.r.t. 5 / 6 (Channel 2)*

$$\begin{array}{ll} U_o = 10.5V & C_i = 0 \\ I_o = 14mA & L_i = 0 \\ P_o = 37mW & \end{array}$$

* For MTL4516, MTL4516C & MTL4517 Models only

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load connected must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR	L/R RATIO (μH/ohm)
IIC	2.41	175		983
IIB**	16.8	680		1,333
IIA	75.0	1,000		1,333
I	95.0	1,000		1,333

** Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is $< 1\%$ of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is $< 1\%$ of the C_o value.
- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than 1μ F for Groups IIB, IIA & I and 600nF for Group IIC.

Schedule 3 – MTL4510 / MTL4510B / MTL4513 Switch / Proximity Detector Interface

The MTL4510 Switch / Proximity Detector Interface is designed to restrict the transfer of energy from the unspecified non-hazardous area apparatus to four intrinsically safe circuits by limitation of voltage and current. An isolating transformer and an opto-coupler provide galvanic isolation between the hazardous and non-hazardous area circuitry. Each channel of the MTL4510 monitors either a detector or a switch in the hazardous area and controls a non-hazardous area load via a solid-state output.

The apparatus comprises an isolating transformer, an opto-coupler, zener diodes and resistors to provide voltage and current limitation. The above, together with other electronic components are mounted on a single printed circuit board (PCB) and housed in moulded plastic enclosure. Polarised plugs and sockets are provided for hazardous and nonhazardous area connections. LED indication is provided to indicate power-on, the status of each output and Line Fault Detection (LFD).

The MTL4510B Multifunction Digital Input Interface has the same hazardous area circuitry and parameters as the MTL4510 but has a different configuration via the removal of a link in the non-hazardous area circuitry.

The MTL4513 Switch / Proximity Detector Interface is a depopulated version of the MTL4510, using the same PCB and enclosure having only two channels populated.

Input / Output Parameters

Non-Hazardous Area Terminals 7 to 14

$$U_m = 253V$$

The circuit connected to non-hazardous area terminals 7 to 14 are designed to operate from a d.c. supply voltage of 35V d.c.

Hazardous Area Terminals 1 w.r.t. 2 (Channel 1)

Hazardous Area Terminals 3 w.r.t. 2 (Channel 2)

Hazardous Area Terminals 4 w.r.t. 5 (Channel 3)*

Hazardous Area Terminals 6 w.r.t. 5 (Channel 4)*

$$U_o = 10.5V$$

$$I_o = 14mA$$

$$P_o = 37mW$$

$$C_i = 0$$

$$L_i = 0$$

* For MTL4510 & MTL4510B Models only

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load connected must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR	L/R RATIO ($\mu H/ohm$)
IIC	2.41	175		983
IIB**	16.8	680		1,333
IIA	75.0	1,000		1,333
I	95.0	1,000		1,333

SGS Baseefa Limited
Rockhead Business Park
Staden lane, Buxton, Derbyshire
SK17 9RZ
United
Kingdom



ANNEX to IECEx BAS 23.0011

Issue No. 1

Date: 12 December 2023

** Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is $< 1\%$ of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is $< 1\%$ of the C_o value.
- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu\text{F}$ for Groups IIB, IIA & I and 600nF for Group IIC.

Schedule 4 – MTL4514D Single Channel Switch / Proximity Detector Interface with Dual Output, Line Fault Detection & Phase Reversal

The MTL4514D Single Channel Switch / Proximity Detector Interface with Dual Output, Line Fault Detection & Phase Reversal is designed to restrict the transfer of energy from unspecified non-hazardous area equipment to an intrinsically safe circuit by limitation of voltage and current. Relays and a transformer provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The interface monitors either a detector or switch located in the hazardous area and controls two non-hazardous area loads via relays. The interface is also fitted with independent phase reversal controls and Line Fault Detection (LFD) circuitry allowing an alarm condition to be signalled for either state, set by switches on the side of the interface.

The equipment comprises an isolating transformer, relays, zener diodes and current limiting resistors to provide voltage and current limitation.

These, together with other electronic components are mounted on a single printed circuit board and housed in a plastic enclosure. Polarised plug and socket connections are provided for connection to the hazardous and non-hazardous area. LED indication is provided to indicate Power-on, state of the output and LFD status.

Input / Output Parameters

Non-Hazardous Area Terminals 7 to 14

$$U_m = 253V$$

The circuit connected to non-hazardous area terminals pins 13 & 14 are designed to operate from a d.c. supply voltage of up to 35V d.c.

Non-hazardous area terminals pins 7, 8, 10 & 11 are connected to relay contacts which can switch up to 253V r.m.s, 2A r.m.s and 100VA.

Hazardous Area Terminals 1 w.r.t. 2 / 3

$$\begin{aligned} U_o &= 10.5V & C_i &= 0 \\ I_o &= 14mA & L_i &= 0 \\ P_o &= 37mW \end{aligned}$$

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the hazardous area terminals must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR	L/R RATIO ($\mu H/ohm$)
IIC	2.41	175		983
IIB**	16.8	680		1,333
IIA	75.0	1,000		1,333
I	95.0	1,000		1,333

** Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

SGS Baseefa Limited
Rockhead Business Park
Staden lane, Buxton, Derbyshire
SK17 9RZ
United
Kingdom



ANNEX to IECEx BAS 23.0011

Issue No. 1

Date: 12 December 2023

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is $< 1\%$ of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is $< 1\%$ of the C_o value.

- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu\text{F}$ for Groups IIB, IIA & I and 600nF for Group IIC.

Schedule 5 – MTL4514N / MTL4514X Switch / Proximity Detector Interface with Line Fault Detection Alarm

The MTL4514N / MTL4514X Switch / Proximity Detector Interface with Line Fault Detection alarm are designed to restrict the transfer of energy from unspecified non-hazardous area apparatus to an intrinsically safe circuit by limitation of voltage and current. Relays and a transformer provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The interface monitors either a detector or switch located in the hazardous area and control a non-hazardous area loads via relay. The interface is also fitted with independent phase reversal controls and Line Fault Detection (LFD) circuitry allowing an alarm condition to be signalled for either state, set by switches on the side of the interface. The interface has identification circuitry fitted on the non-hazardous area side of the circuit which allows it to be identified when fitted on specific backplanes.

The apparatus comprises an isolating transformer, relays, zener diodes and current limiting resistors to provide voltage and current limitation. These, together with other electronic components are mounted on a single printed circuit board and housed in a plastic enclosure. Polarised plug and socket connections are provided for connection to the hazardous and non-hazardous area. LED indication is provided to indicate Power-on, state of the output and LFD status.

Input / Output Parameters

Non-Hazardous Area Terminals 7 to 14

$$U_m = 253V$$

The circuit connected to non-hazardous area terminals pins 13 & 14 are designed to operate from a d.c. supply voltage of up to 35V d.c.

Non-hazardous area terminals pins 7 to 12 are connected to relay contacts which can switch up to 253V r.m.s, 2A r.m.s and 100VA.

Hazardous Area Terminals 1 w.r.t. 2 / 3

$$\begin{aligned} U_o &= 10.5V & C_i &= 0 \\ I_o &= 14mA & L_i &= 0 \\ P_o &= 37mW \end{aligned}$$

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the hazardous area terminals must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR	L/R RATIO ($\mu H/ohm$)
IIC	2.41	175		983
IIB**	16.8	680		1,333
IIA	75.0	1,000		1,333
I	95.0	1,000		1,333

** Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is < 1% of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.

SGS Baseefa Limited
Rockhead Business Park
Staden lane, Buxton, Derbyshire
SK17 9RZ
United
Kingdom



ANNEX to IECEx BAS 23.0011

Issue No. 1

Date: 12 December 2023

- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
- the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu\text{F}$ for Groups IIB, IIA & I and 600nF for Group IIC.

Schedule 6 – MTL5501-SR Failsafe Switch / Proximity Detector Interface

The MTL5501-SR Failsafe Switch / Proximity Detector Interface is designed to provide an interface between unspecified non-hazardous area apparatus and intrinsically safe circuit in the hazardous area. The apparatus is intended to provide a galvanically isolated fail-safe safe-area output whilst monitoring a fail-safe proximity switch detector located in the hazardous area. Line Fault Detection (LFD) in the apparatus is provided by volt-free relay contact output on the nonhazardous area side of the apparatus. Two transformers and a relay provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The apparatus comprises two isolating transformers, a relay, fuses, zener diodes and resistors to provide voltage and current limitation. The above, together with other electronic components are mounted on a printed circuit board and housed in a moulded plastic enclosure. Polarised plugs and sockets are provided for hazardous and non-hazardous area connections. LED indication is provided for power-on, the output status and line fault detection.

Input / Output Parameters

Non-Hazardous Area Terminals 7, 8, 10, 11, 13 & 14

$$U_m = 253V \text{ r.m.s.}$$

The circuit connected to non-hazardous area terminals 13 & 14 is designed to operate from a d.c. supply voltage of up to 35V.

The non-hazardous area terminals 10 & 11 are connected to relay contacts which can switch up to 253V r.m.s, 2A r.m.s and 100VA

Hazardous Area Terminals 1 & 2

$$\begin{array}{ll} U_o = \pm 9.7V & C_i = 0 \\ I_o = 30mA & L_i = 0 \\ P_o = 0.07W & \end{array}$$

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load connected must not exceed the following values:

GROUP	CAPACITANCE (μ F)	INDUCTANCE (mH)	OR	L/R RATIO (μ H/ohm)
IIC	3.5	39		475
IIB*	24	145		1,829
IIA	170	299		3,093
I	320	501		6,414

* Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is < 1% of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.

SGS Baseefa Limited
Rockhead Business Park
Staden lane, Buxton, Derbyshire
SK17 9RZ
United
Kingdom



ANNEX to IECEx BAS 23.0011

Issue No. 1

Date: 12 December 2023

- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
- the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu\text{F}$ for Groups IIB, IIA & I and 600nF for Group IIC.

Schedule 7 – MTL5510 / MTL5510B / MTL5513 Switch / Proximity Detector Interface

The MTL5510 Switch / Proximity Detector Interface is designed to restrict the transfer of energy from the unspecified non-hazardous area apparatus to four intrinsically safe circuits by limitation of voltage and current. An isolating transformer and an opto-coupler provide galvanic isolation between the hazardous and non-hazardous area circuitry. Each channel of the MTL5510 monitors either a detector or a switch in the hazardous area and controls a non-hazardous area load via a solid state output.

The apparatus comprises an isolating transformer, an opto-coupler, zener diodes and resistors to provide voltage and current limitation. The above, together with other electronic components are mounted on a single printed circuit board (PCB) and housed in moulded plastic enclosure. Polarised plugs and sockets are provided for hazardous and non-hazardous area connections. LED indication is provided to indicate power-on, the status of each output and Line Fault Detection (LFD).

The MTL5510B Multifunction Digital Input Interface has the same hazardous area circuitry and parameters as the MTL5510 but has a different configuration via the removal of a link in the non-hazardous area circuitry.

The MTL5513 Switch / Proximity Detector Interface is a depopulated version of the MTL5510, using the same PCB and enclosure having only two channels populated.

Input / Output Parameters

Non-Hazardous Area Terminals 7 to 14

$$U_m = 253V$$

The circuit connected to non-hazardous area terminals 7 to 14 are designed to operate from a d.c. supply voltage of 35V d.c.

Hazardous Area Terminals 1 w.r.t. 2 (Channel 1)

Hazardous Area Terminals 3 w.r.t. 2 (Channel 2)

Hazardous Area Terminals 4 w.r.t. 5 (Channel 3)*

Hazardous Area Terminals 6 w.r.t. 5 (Channel 4)*

$$U_o = 10.5V$$

$$I_o = 14mA$$

$$P_o = 37mW$$

$$C_i = 0$$

$$L_i = 0$$

* For MTL5510 & MTL5510B Models only

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load connected must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR	L/R RATIO ($\mu H/ohm$)
IIC	2.41	175		983
IIB**	16.8	680		1,333
IIA	75.0	1,000		1,333
I	95.0	1,000		1,333

** Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

SGS Baseefa Limited
Rockhead Business Park
Staden lane, Buxton, Derbyshire
SK17 9RZ
United
Kingdom



ANNEX to IECEx BAS 23.0011

Issue No. 1

Date: 12 December 2023

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is $< 1\%$ of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is $< 1\%$ of the C_o value.

- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu\text{F}$ for Groups IIB, IIA & I and 600nF for Group IIC.

Schedule 8 – MTL5511 / MTL5514 / MTL5514-T / MTL5516C / MTL5517 Switch / Proximity Detector Interface

The MTL5511 / MTL5514 / MTL5514-T / MTL5516C / MTL5517 Switch / Proximity Detector Interface are designed to restrict the transfer of energy from unspecified non-hazardous area apparatus to up to two intrinsically safe circuits by limitation of voltage and current. A transformer and relays provide galvanic isolation between the hazardous and non-hazardous area circuitry.

Each channel of the interface monitors either a detector or switch located in the hazardous area and controls non-hazardous area loads via relays. Some models of the interface are fitted with independent phase reverse controls and Line Fault Detection (LFD) circuitry allow an alarm condition to be signalled for either state, set by switches on the side of the interface.

The apparatus comprises an isolating transformer, relays, zener diodes and current limiting resistors to provide voltage and current limitation on each channel. These, together with other electronic components are mounted on a single printed circuit board and housed in a plastic enclosure. Polarised plugs and sockets are provided for connection to the hazardous and non-hazardous area. LED indication is provided to indicate Power-on, state of the outputs and LFD status.

The above listed models are all built on a common printed circuit board. The differences between the models relates to the configuration of the relays and non-hazardous connections via the fitting and removal of relays and soldered and component links.

The MTL5514-T Single Channel Switch / Proximity Detector Interface with Line Fault Detection (LFD) Alarm is of similar construction to the MTL5514 variant of the equipment with the same input and output parameters, but has an extended ambient temperature range of -20°C to +65°C.

Model Range:

Model No.	
MTL5511	Single Channel Switch / Proximity Detector Interface
MTL5514	Single Channel Switch / Proximity Detector Interface with Line Fault Detection (LFD) Alarm
MTL5514-T	Single Channel Switch / Proximity Detector Interface with Line Fault Detection (LFD) Alarm
MTL5516C	Two Channel Switch / Proximity Detector Interface
MTL5517	Two Channel Switch / Proximity Detector Interface with Line Fault Detection (LFD) Alarm

Input / Output Parameters

Non-Hazardous Area Terminals 7 to 14

$$U_m = 253V \text{ r.m.s.}$$

The circuit connected to non-hazardous area terminals 13 & 14 is designed to operate from a d.c. supply voltage of up to 35V.

Non-hazardous area terminals 7 to 12 are connected to relay contacts which can switch up to 253V r.m.s, 2A r.m.s. and 100VA.

Hazardous Area Terminals 1 w.r.t. 2 / 3 (Channel 1)

Hazardous Area Terminals 4 w.r.t. 5 / 6 (Channel 2)*

$$\begin{array}{lll} U_o = & 10.5V & C_i = 0 \\ I_o = & 14mA & L_i = 0 \\ P_o = & 37mW & \end{array}$$

* For MTL5516C & MTL5517 Models only

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load connected must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR	L/R RATIO (μH/ohm)
IIC	2.41	175		983
IIB**	16.8	680		1,333
IIA	75.0	1,000		1,333
I	95.0	1,000		1,333

** Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is $< 1\%$ of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is $< 1\%$ of the C_o value.
- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than 1μ F for Groups IIB, IIA & I and 600nF for Group IIC.

Schedule 9 – MTL5514D Single Channel Proximity Detector Interface with Dual Output, Line Fault Detection & Phase Reversal

The MTL5514D Single Channel Switch / Proximity Detector Interface with Dual Output, Line Fault Detection & Phase Reversal is designed to restrict the transfer of energy from unspecified non-hazardous area apparatus to an intrinsically safe circuit by limitation of voltage and current. Relays and a transformer provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The interface monitors either a detector or switch located in the hazardous area and controls two non-hazardous area loads via relays. The interface is also fitted with independent phase reversal controls and Line Fault Detection (LFD) circuitry allowing an alarm condition to be signalled for either state, set by switches on the side of the interface.

The apparatus comprises an isolating transformer, relays, zener diodes and current limiting resistors to provide voltage and current limitation.

These, together with other electronic components are mounted on a single printed circuit board and housed in a plastic enclosure. Polarised plug and socket connections are provided for connection to the hazardous and non-hazardous area. LED indication is provided to indicate Power-on, state of the output and LFD status.

Input / Output Parameters

Non-Hazardous Area Terminals 7 to 14

$$U_m = 253V \text{ r.m.s.}$$

The circuit connected to non-hazardous area terminals pins 13 & 14 is designed to operate from a d.c. supply voltage of up to 35V d.c.

Non-hazardous area terminals pins 7 to 12 are connected to relay contacts which can switch up to 253V r.m.s, 2A r.m.s. and 100VA.

Hazardous Area Terminals 1 w.r.t. 2 / 3

$$\begin{aligned} U_o &= 10.5V & C_i &= 0 \\ I_o &= 14mA & L_i &= 0 \\ P_o &= 37mW \end{aligned}$$

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area terminals must not exceed the following values:

GROUP	CAPACITANCE (μ F)	INDUCTANCE (mH)	OR	L/R RATIO (μ H/ohm)
IIC	2.41	175		983
IIB**	16.8	680		1,333
IIA	75.0	1,000		1,333
I	95.0	1,000		1,333

** Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

SGS Baseefa Limited
Rockhead Business Park
Staden lane, Buxton, Derbyshire
SK17 9RZ
United
Kingdom



ANNEX to IECEx BAS 23.0011

Issue No. 1

Date: 12 December 2023

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is $< 1\%$ of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is $< 1\%$ of the C_o value.

- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu\text{F}$ for Groups IIB, IIA & I and 600nF for Group IIC.