



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx CML 14.0001	Page 1 of 4	<u>Certificate history:</u>
Status:	Current	Issue No: 7	Issue 6 (2016-07-13)
Date of Issue:	2016-09-02		Issue 5 (2016-04-01)
Applicant:	Raytec Ltd Unit 3, Wansbeck Business Park Rotary Parkway Ashington Northumberland NE63 8QW United Kingdom		Issue 4 (2015-08-21)
Equipment:	Spartan SPX Luminaires		Issue 3 (2015-05-15)
Optional accessory:			Issue 2 (2015-02-17)
Type of Protection:	Increased safety, encapsulated, dust, flameproof protection		Issue 1 (2014-12-18)
Marking:	Ex e mb IIC T6/T5/T6 Gb Ex db e mb IIC T6 Gb Ex tb III C T82°C/T98°C Db Up to -52°C to +55°C Marking dependant on model, refer to Annex		Issue 0 (2014-04-28)

Approved for issue on behalf of the IECEx
Certification Body:

H M Amos MIET

Position:

Technical Manager

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Certification Management Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port, CH65 4LZ
United Kingdom





IECEx Certificate of Conformity

Certificate No.: **IECEx CML 14.0001**

Page 2 of 4

Date of issue: 2016-09-02

Issue No: 7

Manufacturer: **Raytec Ltd**
Unit 3, Wansbeck Business Park
Rotary Parkway
Ashington
Northumberland
NE63 8QW
United Kingdom

Manufacturing locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2011](#) Explosive atmospheres - Part 0: General requirements
Edition:6.0

[IEC 60079-1:2014](#) Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

[IEC 60079-18:2009](#) Explosive atmospheres Part 18: Equipment protection by encapsulation "m"
Edition:3

[IEC 60079-31:2013](#) Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

[IEC 60079-7:2006](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:4

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/CML/ExTR14.0001/00](#)
[GB/CML/ExTR15.0039/00](#)
[GB/CML/ExTR16.0095/00](#)

[GB/CML/ExTR14.0006/00](#)
[GB/CML/ExTR15.0060/00](#)
[GB/CML/ExTR16.0121/00](#)

[GB/CML/ExTR14.0025/00](#)
[GB/CML/ExTR16.0032/00](#)

Quality Assessment Reports:

[GB/SIR/QAR13.0018/00](#)

[GB/SIR/QAR13.0018/01](#)

[GB/SIR/QAR13.0018/02](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx CML 14.0001**

Page 3 of 4

Date of issue: 2016-09-02

Issue No: 7

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Spartan SPX FL** luminaire is fitted with LED lamp modules and is rated at 110V to 254 V, 50/60 Hz. The luminaire may be supplied with a battery pack and inverter to enable operation in 'emergency' mode. The luminaire enclosure comprises, front, centre, and rear cast aluminium housings that are fixed together with bolts. There are fixing points for a mounting bracket that enable the luminaire to be fixed in any orientation, alternative fixing points are also provided for additional mounting accessories. Inside the centre housing there are two independent encapsulated power supplies (electronic control gear) and supply /connection terminal blocks, cable entries are also present for the connection of mains electrical supply. Internal and external earth points are available. The front housing has a toughened soda lime glass lens that is available in clear or coloured options. Internally the LED's are mounted onto two independent IMS PCBs which are attached to the rear heat sink, each PCB utilises twelve LED's which can be white, infra-red, coloured or a combination.

The LED's must be fitted with individual optics, these optics are available in a range of beam patterns to suit the end user application. The LED's/optics are positioned in groups of four, each group of four is in turn covered with an individual clear polycarbonate cover which is then partially encapsulated.

See Annex for full description and Conditions of Manufacture

SPECIFIC CONDITIONS OF USE: NO



IECEx Certificate of Conformity

Certificate No.: **IECEx CML 14.0001**

Page 4 of 4

Date of issue: 2016-09-02

Issue No: 7

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)
See annex for full history of certificate
changes

Annex:

[IECEx CML 14_0001 Annex Issue 7.pdf](#)

Annexe to: IECEx CML 14.0001 Issue 7
Applicant: Raytec Ltd.
Apparatus: Spartan SPX FL** Luminaire



Marking

FL** Versions	BL** Version	BL** Emergency Version
Ex e mb IIC T6 Gb Ta= Up to -52°C to +48°C	Ex e mb IIC T5 Gb Ta= Up to -52°C to +48°C	Ex e mb IIC T5 Gb Ex tb IIIC T98°C Db Ta= -20°C to +46°C
Ex e mb IIC T5 or T4 Gb Ex tb IIIC T82°C Db Ta= Up to -52°C to +55°C	Ex e mb IIC T4 Gb Ex tb IIIC T98°C Db Ta= Up to -52°C to +55°C	IP66
IP66	IP66	

All Emergency variants have a lower ambient of -20°C only

Sockets Fitted:
Ex db e mb IIC T6 Gb
Ex tb IIIC T82°C Db
Ta= Up to -20°C to +40°C

Socket GHG 54 Fitted:**
Ex db e mb IIC T6 Gb
Ta= Up to -20°C to +40°C

When latest version of GHG 5118*** socket is fitted lower ambient may be marked -55°C

Description

The Spartan SPX FL** luminaire is a range of LED luminaires. There are three sizes available in the range FL12 (Small) FL24 (Medium) and FL48 (Large). All size enclosures are offered as LV (Low Voltage); rated at 18V - 48V AC / 18V – 68V DC or HV (High Voltage); rated at 110V – 254V AC. The HV luminaires may be supplied with a battery pack and inverter to enable operation in 'emergency' mode.

The luminaire enclosure comprises, front, centre, and rear cast aluminium housings that are fixed together with bolts. There are fixing points for a mounting bracket that enable the luminaire to be fixed in any orientation, alternative fixing points are also provided for additional mounting accessories.

Inside the centre housing there are two independent encapsulated power supplies (electronic control gear) and supply /connection terminal blocks, cable entries are also present for the connection of mains electrical supply. Internal and external earth points are available.

The front housing has a soda lime toughened glass lens that is available in clear or coloured options. Internally the LED's are mounted onto two independent IMS PCBs which are attached to the rear heat sink, each PCB utilises twelve LED's which can be white, infra-red, coloured or a combination.

The LED's must be fitted with individual optics, these optics are available in a range of beam patterns to suit the end user application. The LED's/optics are positioned in groups of four, each

Unit 1, Newport Business Park
New Port Road
Ellesmere Port
CH65 4LZ

T +44 (0) 151 559 1160
E info@cmlex.com

www.cmlex.com

Company Reg No. 8554022 VAT No. GB163023642



group of four is in turn covered with an individual clear polycarbonate cover which is then partially encapsulated.

The emergency version utilises a modified rear housing which incorporates a rechargeable battery pack, connection terminal block and encapsulated fuse. An optional encapsulated single green LED can be fitted to the wall of the centre housing which provides the end user with an indication that the emergency system is healthy.

The luminaire is available in three sizes, small, medium and large. The medium variant as described above, the small variant which only utilises one power supply/LED board and the larger variants which consist of a number of medium luminaires fixed together with unions and alternative mounting brackets.

The small, medium and large variants may all be fitted with an optional encapsulated photocell which is located in the wall of the centre housing positioned to suit the customer's application. Also on all variants a 'Vario' holographic diffuser film may be fitted behind the glass to give alternative light patterns. The front and middle/rear housing of the luminaires may be split to allow the LED assembly to be mounted remotely from the power supply/emergency enclosure.

An EMC filter module may be fitted as an optional extra, this is an additional encapsulated board, located in place of the terminal block bracket (when fitted).

A Spartan SPX FLT** transportable variant of luminaire is available which consists of one of the luminaires above mounted in a sturdy frame and supplied with suitable cable and certified ATEX plugs and sockets.

A Bulkhead variant of the luminaire is available, the Spartan SPX BL24. Based on the FL24 floodlight it is modified to utilise a narrower enclosure and run at half of the power. It is offered as standard with the LV version, HV version or as HV emergency where it is supplied with a battery pack and inverter.

The BL24 is designed for wall mounting in any orientation using steel brackets at the back of the luminaire. The enclosure consists of a front cover and rear body and utilises the power supply, inverter, control board and modified light engine from the FL24. The BL luminaire can be offered as transportable and with an optional photo cell.

The FL 12, FL 24 and BL 24 are offered as portable variants FLP 12, FLP 24 and BLP 24.

The SPX range may be fitted with a selection of separately certified sockets mounted onto the back of the existing luminaire enclosures. When sockets are mounted onto the portable variants they are fitted with an essential carrying frame.

An optional replaceable antistatic lens film is available across the range.

The equipment may be fitted with alternative labels, when fitted with these labels, the equipment is marketed under the product range name HAZX Nero and carry the following alternative model names:

Original model name	Alternative model name
FL12	HAZ-NER-M
FL24	HAZ-NER-S
FL48	HAZ-NER-D
FL72	HAZ-NER-T
BL24	HAZ-NEB-S
FLP12	HAZ-NEP-M
FLP24	HAZ-NEP-S
BLP24	HAZ-NEP-B
FLT24	HAZ-NET-S

Condition of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- Where the product incorporates certified components the manufacturer shall ensure that any changes to those components do not affect the compliance of the certified product that is the subject of this certificate.
- A dielectric strength test shall be carried out on all units manufactured in accordance with EN 60079-7:2007 clause 7.1 and EN 60079-18:2009, clause 9.2, at 1508 Vac for 1 minute, or alternatively at 1.2 times this test voltage for 100 ms. Alternatively, a 1.4 times d.c. voltage dielectric strength test may be carried out. No breakdown shall occur. Tests shall be carried out between each circuit and earth and between each circuit and the surface of encapsulated parts.
- A visual inspection shall be carried out on the encapsulated parts to check for damage, in accordance with EN 60079-18:2009, clause 9.1.

Condition of Certification

None

Details of Certificate Changes

Issue This Issue introduced the following changes:

1

- 1 To allow a Low Voltage Power Supply option and subsequent amendment to the condition of manufacture for electric strength testing.
- 2 To include a cable lengthening and repair procedure to the constructional drawings.
- 3 To include clarification notes to the constructional drawings.
- 4 To include change to conductors of cables entering encapsulate for PSU's and LED's.

Issue This Issue introduced the following changes:

2

- 1 The introduction of an alternative bulkhead luminaire version, housed in a modified enclosure. The battery pack and inverter modules have been changed as part of this addition.

Issue This Issue introduced the following changes:

3

- 1 To permit the use of alternative terminal blocks

Issue This Issue introduced the following changes:

4

- 1 To allow an additional larger FL72 (X Large) version to be included for use in the Spartan SPX FL** Luminaire range.

Issue This Issue introduced the following changes:

5

- 1 To allow transparent antistatic film to be fitted to the outer lens cover.
- 2 To allow separately certified panel mounted socket connectors to be fitted.
- 3 To allow a portable range of luminaires to be included.
- 4 Description amended to reflect the modifications above and to correct a reference typographical error.

Issue This Issue introduced the following changes:

6

- 1 To increase the voltage range for the low voltage options. The product description was updated to reflect the changes made by this variation.

Issue This Issue introduced the following changes:

7

- 1 To allow an alternative label to be fitted
- 2 To allow the use of alternative model names