



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX IBE 13.0004X** Page 1 of 4 Certificate history:
Status: **Current** Issue No: 1 Issue 0 (2013-03-26)
Date of Issue: 2021-11-04
Applicant: **Weidmüller Interface GmbH & Co. KG**
Klingenbergstrasse 26
Detmold 32758
Germany
Equipment: **Junction enclosure Klippon® POK...Ex**
Optional accessory:
Type of Protection: **Protection by increased safety "e", Protection by intrinsic safety "i", Protection by enclosure "t"**
Marking: Ex eb IIC T6...T5 Gb
Ex eb ia IIC T6...T5 Gb
Ex ia IIC T6...T5 Ga
Ex tb IIIC T85 °C...T100 °C Db

Approved for issue on behalf of the IECEx
Certification Body:

Alexander Henker

Position:

Deputy Head of department Certification Body

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

IBExU Institut für Sicherheitstechnik GmbH
Fuchsmühlenweg 7
09599 Freiberg
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX IBE 13.0004X**

Page 2 of 4

Date of issue: 2021-11-04

Issue No: 1

Manufacturer: **Weidmüller Interface GmbH & Co. KG**
Klingenbergstrasse 26
Detmold 32758
Germany

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-11:2011](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

[IEC 60079-31:2013](#) Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[DE/IBE/ExTR13.0004/00](#)

[DE/IBE/ExTR13.0004/01](#)

Quality Assessment Report:

[NL/DEK/QAR12.0052/07](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX IBE 13.0004X**

Page 3 of 4

Date of issue: 2021-11-04

Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Junction enclosures Klippon POK...Ex made of glass fibre reinforced polyester

Ambient temperature range: T6 / T85 °C → -55 °C to +40 °C

T5 / T100 °C → -55 °C to +55 °C

Degree of protection: IP66

Enclosures type	Length	Width	Depth
Klippon POK 080806 Ex	75 mm	80 mm	55 mm
Klippon POK 081106 Ex	75 mm	110 mm	56 mm
Klippon POK 081606 Ex	75 mm	160 mm	56 mm
Klippon POK 081906 Ex	75 mm	190 mm	55 mm
Klippon POK 082306 Ex	75 mm	230 mm	56 mm
Klippon POK 121209 Ex	120 mm	122 mm	90 mm
Klippon POK 122209 Ex	120 mm	220 mm	90 mm
Klippon POK 161609 Ex	160 mm	160 mm	90 mm
Klippon POK 162609 Ex	160 mm	260 mm	90 mm
Klippon POK 163609 Ex	160 mm	360 mm	90 mm
Klippon POK 165609 Ex	160 mm	560 mm	90 mm
Klippon POK 252512 Ex	250 mm	255 mm	120 mm
Klippon POK 254012 Ex	250 mm	400 mm	120 mm
Klippon POK 256012 Ex	250 mm	600 mm	120 mm
Klippon POK 404012 Ex	405 mm	400 mm	120 mm
Klippon POK 252516 Ex	250 mm	255 mm	160.5 mm
Klippon POK 254016 Ex	250 mm	400 mm	160.5 mm

Further identical constructed enclosures can be manufactured with in between sizes.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The applicable temperature ranges for the ambient temperature depending on the temperature class/max. surface temperature must be observed.
- The values are maximum values, the actual electrical values are determined by the built-in components. The manufacturer fixes the definite rated values in the context of these limiting values. So the manufacturer ensures the compliances with the maximum surface temperature and the permissible operating temperature of the components.
- The conditions specified in the certificates of the Ex components have to be taken into account for the installation of these components in the enclosure.



IECEX Certificate of Conformity

Certificate No.: **IECEX IBE 13.0004X**

Page 4 of 4

Date of issue: 2021-11-04

Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

The device meets the requirements of the current standards IEC 60079-0, Ed. 7.0, IEC 60079-7, Ed. 5.1 and IEC 60079-31, Ed. 2.0.